



CERTIFICATE OF ACCREDITATION

The ANSI National Accreditation Board

Hereby attests that

Doble Engineering Company
1000 South Loop West, Suite 100
Houston, Texas 77054

Fulfills the requirements of

ISO/IEC 17025:2017

In the field of

TESTING

This certificate is valid only when accompanied by a current scope of accreditation document.
The current scope of accreditation can be verified at www.anab.org.

A handwritten signature in black ink, appearing to be 'Jason Stine', is positioned above a horizontal line.

Jason Stine, Vice President

Expiry Date: 05 December 2026

Certificate Number: AT-2637.03



This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017.
This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory
quality management system (refer to joint ISO-ILAC-IAF Communiqué dated April 2017).



SCOPE OF ACCREDITATION TO ISO/IEC 17025:2017

Doble Engineering Company

1000 South Loop West, Suite 100
Houston, Texas 77054

Vernon Glover
713-741-7148

TESTING

Valid to: **December 5, 2026**

Certificate Number: **AT-2637.03**

Chemical

Specific Tests and/or Properties Measured	Specification, Standard, Method, or Test Technique	Items, Materials or Product Tested	Key Equipment or Technology
Dissolved Gas Analysis	ASTM D3612, Method C, IEC 60567	Dielectric Fluid	Gas Chromatography
Moisture	ASTM D1533/IEC 60814	Dielectric Fluid	Karl Fischer Automatic Titration
Neutralization Number	ASTM D974	Dielectric Fluid	Titration
Dielectric Breakdown	ASTM D1816	Dielectric Fluid	Oil Breakdown Voltage Tester
Dielectric Breakdown	ASTM D877	Dielectric Fluid	Oil Breakdown Voltage Tester
Power Factor	ASTM D924/IEC 60247	Dielectric Fluid	Oil Tester
Interfacial Tension	ASTM D971	Dielectric Fluid	Automatic / Manual Force Tensiometer
Specific Gravity	ASTM D4052	Dielectric Fluid	Automatic Densitometer
Color of Petroleum Products	ASTM D1500	Dielectric Fluid	Visual Color Comparator Instrument
Visual Examination	ASTM D1524	Dielectric Fluid	Visual
Corrosive Sulfur	ASTM D1275	Dielectric Fluid	Copper/Silver strip Polishing/Tarnishing

Note:

1. This scope is formatted as part of a single document including Certificate of Accreditation No. AT-2637.03.



Jason Stine, Vice President

