PCI-600 PRIMARY CURRENT INJECTION DEVICE

USER'S MANUAL







TEL: (909) 923-9390 FAX: (909) 923-9391 May 2025 Revision 2.1

SAFETY SUMMARY

FOLLOW EXACT OPERATING PROCEDURES

Any deviation from the procedures described in this User's Manual may create one or more safety hazards, may damage the PCI-600, or cause errors in the test results. Vanguard Instruments Company, Inc. assumes no liability for unsafe or improper use of the PCI-600.

All safety precautions provided in this manual must be observed during all phases of testing including test preparation, test lead connection, actual testing, and test lead disconnection.

SAFETY WARNINGS AND CAUTIONS

Only trained operators shall use this device. All circuits under test shall be off-line and fully isolated.

DO NOT MODIFY TEST EQUIPMENT

To avoid the risk of introducing additional or unknown hazards, do not install substitute parts or perform any unauthorized modification to any PCI-600 test unit. To ensure that all designed safety features are maintained, it is highly recommended that repairs be performed only by Vanguard Instruments Company factory personnel or by an authorized repair service provider. Unauthorized modifications can cause safety hazards and will void the manufacturer's warranty.

TABLE OF CONTENTS

CONVENTIONS USED IN THIS DOCUMENT	1
1.0 INTRODUCTION	2
1.1 General Description and Features	2
1.2 PCI-600 Technical Specifications	3
1.3 Controls and Indicators	4
2.0 OPERATING PROCEDURES	6
2.1 Functional Description	6
2.1.1. AC Current Source	6
2.1.2. Current Output Control	6
2.1.3. Timer Stop Input and Control	7
2.1.4. External Current Input	8
2.1.5. LCD Contrast Control	8
2.2 Performing Tests	9
2.2.1. Testing the Open Time Delay of a Protection Relay	9
2.2.2. Measuring Current Transformer Primary and Secondary Currents	11

LIST OF TABLES

Table 1. PCI-600 Technical Specifications	. 3
Table 2. Functional Descriptions of PCI-600 Controls and Indicators	. 5
Table 3. Current Output vs. Time	. 6

LIST OF FIGURES

Figure 1. PCI-600 Controls and Indicators	۷	5 4
---	---	-----

CONVENTIONS USED IN THIS DOCUMENT

This document uses the following conventions:

- A key, switch, input, or knob on the PCI-600 is indicated as **[KEY]**, **[SWITCH]**, **[INPUT]**, **[KNOB]**.
- Menu options are referenced as (MENU OPTION).
- PCI-600 LCD screen output is shown as:

l.	OPTION	l	
2.	OPTION	2	
з.	OPTION	З	
4.	OPTION	4	

• Warning messages are indicated as:



• Important notes are indicated as:



1.0 INTRODUCTION

1.1 General Description and Features

The PCI-600 is a programmable AC high-current source designed specifically for utilitysubstation applications. This device is well suited for primary injection testing of protective relays. This versatile device can also be used for testing thermal, magnetic, and solid-state motor-protection relays and molded-case circuit-breakers, as well as any application that requires a high-current source.

Built-in Timer

The PCI-600's built-in timer can test the time-delay characteristics of protection relays and molded-case circuit-breakers. Once the test is initiated, the current source and the timer are automatically turned on at the next zero-crossing point of the AC. The timer stops when the PCI-600 input detects a change in the dry contact or voltage input, or detects the removal of the test current. The test results are then displayed in milli-seconds and fractions of a cycle(s) on the unit's back-lit LCD screen (20 characters by 4 lines).

Current Source

Test currents, ranging from 10 to 600 amperes, can be set by using the rotary dial knob on the control panel. The test current is then measured, and the results are displayed on the LCD screen. When the PCI-600 is used as a current source, the current-on time (duration of current flow) is displayed on the LCD screen.

External Current Input

The PCI-600 also has an external-current input (0 - 10 A). Both the internal current source amplitude and the external current source measurement readings can be viewed at the same time.

1.2 **PCI-600 Technical Specifications**

Table 1. PCI-600 Technical Specifications

TYPE	100 - 600 Amp current source	
PHYSICAL SPECIFICATIONS	Dimensions: 17"W x 12.5"H x 10.5"D (42.6 cm x 32.0 cm x 27.0 cm); Weight: 46 lbs (21 kg)	
INPUT POWER	100 – 120 Vac or 200 – 240 Vac (factory pre-set), 50/60 Hz	
INTERNAL METER RANGE	100 mA – 1000 A; Accuracy: 1% of reading ±20 mA	
MEASUREMENT METHOD	Isolated CT	
EXTERNAL METER RANGE	10 mA – 10 A; Accuracy: 1% of reading, ±2mA	
MEASUREMENT METHOD	Isolated CT	
TIMER READING RANGE	1ms – 2 hours; Accuracy: 0.1% of reading ±1ms	
TIMER STOP INPUTS	Voltage input (24V – 300V, DC or peak AC), dry contact input, or removal of primary current	
DISPLAY	Back-lit LCD Screen (20 characters by 4 lines); viewable in bright sunlight and low-light levels	
COMPUTER INTERFACE	RS-232C port for factory calibration and diagnostics	
SAFETY	Designed to meet IEC61010 (1995), UL61010A-1, CSA-C22.2 standards	
ENVIRONMENT	Operating: -10°C to 50° C (15°F to +122° F); Storage: -30° C to 70° C (- 22°F to +158° F)	
CABLES	10-foot #1/0 AWG test leads, power cord, ground cable	
OPTIONS	Transportation case	
WARRANTY	One year on parts and labor	



The above specifications are valid at nominal operating voltage and at a temperature of 25°C (77°F). Specifications may change without prior notice.

NOTE

1.3 Controls and Indicators

The PCI-600's controls and indicators are shown in Figure 1. A leader line with an index number points to each control and indicator, which is cross-referenced to a functional description in Table 2. The table describes the function of each item on the control panel. The purpose of the controls and indicators may seem obvious, but users should become familiar with them before using the PCI-600. Accidental misuse of the controls will usually cause no serious harm. Users should also be familiar with the safety summary found on the front page of this User's Manual.



Figure 1. PCI-600 Controls and Indicators

ltem Number	Panel Markings	Functional Description	
1		Current lead connectors	
2		Back-lit LCD screen (20 characters by 4 lines), viewable in bright sunlight and low-light levels.	
3	DRY CONTACT WET CONTACT CURRENT	Timer and current source stop input selection with LED indicator. Stop input mode is selected by using the arrow keys.	
4	TIMER STOP	Timer "STOP" input connectors	
5	EXT CURRENT	External current input connectors	
6		Input power connector	
7		Circuit Breaker/Power Switch	
8	GROUND	PCI-600 ground stud. Connect ground stud to substation ground using provided cable.	
9	CURRENT CONTROL	Current control knob	
10	RS-232C	RS-232C port for factory calibration, diagnostics, and firmware updates	
11	HIGH CURRENT PRESENT	High current presence indicator LED	
12		The up and down arrows are used to control the current source output and timer. Three modes are available: ON+TMR : Turns on current source and timer OFF : Turns off current source and timer MONT : Turns on current source momentarily	
13	CONTRAST	LCD screen contrast control	

Table 2. Functional Descriptions of PCI-600 Controls and Indicators

2.0 OPERATING PROCEDURES

2.1 Functional Description

2.1.1. AC Current Source



AC test currents from 10A to 600A are set by turning the [CURRENT CONTROL] knob on the front panel. The test current is measured and displayed on the LCD screen. The PCI-600 output current ratings are shown in Table 3 below.

Table 3. Current Output vs. Time

Output @ 120 Vac	Output @ 240 Vac	Time
5.6 Vac @ 100 A	9.5 Vac @ 100 A	1 hour
5.3 Vac @ 200 A	9.4 Vac @ 200 A	5 minutes
4.9 Vac @ 300 A	9.0 Vac @ 300 A	2 minutes
4.6 Vac @ 400 A	8.2 Vac @ 400 A	1 minute
4.2 Vac @ 500 A	7.5 Vac @ 500 A	30 seconds
3.9 Vac @ 560 A	7.0 Vac @ 600 A	20 seconds

2.1.2. Current Output Control



The PCI-600 current source output is controlled by the $[\uparrow]$ and $[\downarrow]$ keys. Three control modes are available:

ON + TMR This mode turns on the PCI-600's current source and timer. This initiates a test and is stopped by using the "Timer Stop" inputs. The test results will be displayed on the LCD. The test can be terminated by pressing the [↓] key. The PCI-600's built-in time/cycle counter is used to time events in milliseconds and cycles. The elapsed time is displayed on the LCD along with the test current after a test is completed.

OFF In this mode both the current source output and timer are off.

MONT. This mode turns on the current source momentarily. To turn on the current source, press and hold the [↓] key. The PCI-600 current output can now be set by turning the [CURRENT CONTROL] knob. Release the [↓] key to turn off the current source.

2.1.3. Timer Stop Input and Control



2.1.4. External Current Input



The PCI-600's "EXT CURRENT" input is a 10 ampere AC current meter. This built-in ampere meter allows the user to monitor an AC current. This current input is isolated. A typical application for this feature is to measure a Current Transformer (CT) current ratio. The user can set the PCI-600 to output a current through the CT primary input. The CT secondary output is measured with the PCI-600 "EXT CURRENT" input. Both the PCI-600 output current and the CT secondary current are displayed on the LCD allowing the user to easily calculate the CT current ratio. The External Current's polarity with respect to the PCI-600 drive current is indicated on the LCD by a "+" sign (in phase) or a "-" sign (out of phase). Proper phasing is indicated when the same colored PCI connectors are connected to corresponding terminals on the CT as shown below:



2.1.5. LCD Contrast Control



To change the contrast level on the PCI-600's LCD screen, press and hold the contrast $[\rightarrow]$ key next to the LCD screen. Release the contrast $[\rightarrow]$ key when the desired contrast level has been reached.

2.2 Performing Tests

2.2.1. Testing the Open Time Delay of a Protection Relay

Follow the steps below to test the Open Time Delay of a protection relay:

a. Make cable connections per the illustration below:



- b. Turn the **[CURRENT CONTROL]** knob counter-clockwise to the zero position.
- c. Turn on the power switch. After the initial informational screens, the following screen will be displayed:



d. From the "Timer Stop" section on the control panel, press the [→] key until "DRY CONTACT" is selected as shown below:



e. Press and hold the $[\downarrow]$ key to momentarily turn on the current source:



f. Turn the **[CONTROL KNOB]** clockwise to set the desired current. The screen will be updated as shown below:



- g. Release the $[\downarrow]$ key.
- h. Press the [^] key to select "ON + TMR" mode and start the test:



i. The PCI-600 will inject the preset current into the bus and turn on the timer. The LCD will be updated as shown below:



j. The timer will stop and the current source will turn off when the PCI-600 "TIMER STOP" input detects a change in the relay dry contact, or if the operator presses the [] key to select the "OFF" mode.

2.2.2. Measuring Current Transformer Primary and Secondary Currents

Follow the steps below to measure current transformer primary and secondary currents:

- СВ СТ o 1 90-240 Vac 50-60 Hz, 20A TIMER STOP CURF OFF OFF 0 0 0 -DRY CONTAC -wet contact O-CURREN PCI-600 TM ⊕**....**?⊕ Vanguard Instruments Co., Inc. Ontario, California, USA
- a. Make cable connections per the illustration below:

- b. Turn the **[CURRENT CONTROL]** knob counter-clockwise to the zero position.
- c. Turn on the power switch. The following screen will be displayed:

	(] ZmC	J.OCY
Ext	I:	+0.000	A
Drv	I:	0.00	A

d. Press and hold the $[\downarrow]$ key to momentarily turn on the current source:



e. Turn the [CURRENT CONTROL] knob clockwise to set the desired current. The screen will be updated as shown below:



- f. Release the $[\downarrow]$ key when the desired current is displayed on the screen.
- g. Press the [^] key to select "ON + TMR" mode and start the test:



h. The CT primary and secondary currents will be displayed as well as the polarity as shown below:





The External current polarity is shown either as in-phase ("+" sign) or out of phase ("-" sign) with respect to the PCI-600's drive current.

i. Turn off the current source by pressing the $[\downarrow]$ key.







Copyright © 2025 by Doble Engineering Company

PCI-600 User's Manual • Revision 2.1 • May 21, 2025 • TA